



NOTES:

1. Maximum riser height shall be not more than 7-3/4 inches. The greatest riser height within any flight of stairs shall not exceed the smallest by more than 3/8". R311.7.5.1.
2. The minimum tread depth shall be 10 inches. The tread depth shall be measured horizontally between the vertical planes of the foremost projection of adjacent treads and at right angle to the tread's leading edge. R311.7.5.2.
3. Winder treads shall have a minimum tread depth of 10 inches measured between the vertical planes of the foremost projection of adjacent treads at the intersections with the walkline. R311.7.5.2.1.
4. Winder treads shall have a minimum tread depth of 6 inches at any point within the clear width of the stair. R311.7.5.2.1.
5. Within any flight of stairs, the largest winder tread depth at the walk line shall not exceed the smallest winder tread by more than 3/8 inch. R311.7.5.2.